



FIRE EXTINGUISHER

Customer Information

Name Washtenaw Community College

Building Information

Name Occupational Education OE

Address 4800 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US

Inspection Information

Name Fire Extinguisher

SR# 48332232

Frequency Annual

Timezone GMT-05:00

Account Information

Name Johnson Controls North America

Address 5757 N. Green Bay Ave, Milwaukee, WI 53209

Phone _____

Office _____

License _____

Date 05/13/2021

Inspector _____

License _____

Contact Information

Name Bill Ghrist

Role Manager of Energy and Systems Integration

E-Mail bghrist@wccnet.edu

Phone 17346045511

Building Notes

- Annual Sprinkler Alarm Inspection: June 2020

Tested and inspected all Water Flow Switches, Tamper Switches, & Valves associated with the Sprinkler System.

INSPECTION RESULTS SUMMARY				
DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
ABC Extinguisher	60	55	5	0
Clean Agent Rechargeable	1	1	0	0
Extinguisher - CO2	4	1	3	0
Extinguisher - Dry Chemical	1	0	1	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
ABC Extinguisher	60	5	1	12
Extinguisher - CO2	4	0	0	0
Clean Agent Rechargeable	1	1	0	0
Extinguisher - Dry Chemical	1	0	0	0



FIRE EXTINGUISHER

Customer Information

Name Washtenaw Community College

Building Information

Name Business Education BE

Address 4800 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US

Inspection Information

Name Fire Extinguisher

SR# N/A

Frequency Annual

Timezone GMT-05:00

Account Information

Name Johnson Controls North America

Address 6200 shamrock court Dublin Ohio 43017

Phone _____

Office 54-41-1041

License _____

Date 12/16/2020

Inspector License 54-25-4199

Contact Information

Name Bill Ghrist

Role Manager of Energy and Systems Integration

E-Mail bghrist@wccnet.edu

Phone 17346045511

Building Notes

1. Annual Sprinkler Alarm Inspection: June 2020

Tested and Inspected all Water Flow Switches, Tamper Switches, & Valves associated with the Sprinkler System.

INSPECTION RESULTS SUMMARY				
DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
Clean Agent Rechargeable	2	1	1	0
Extinguisher - CO2	6	5	1	0
Extinguisher - Dry Chemical	13	8	5	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
Extinguisher - CO2	6	0	0	0
Extinguisher - Dry Chemical	13	2	6	0
Clean Agent Rechargeable	2	0	0	1



FIRE EXTINGUISHER

Customer Information

Name Washtenaw Community College

Building Information

Name Business Education BE

Address 4800 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US

Inspection Information

Name Fire Extinguisher

SR# N/A

Frequency Annual

Timezone GMT-05:00

Account Information

Name Johnson Controls North America

Address 5757 N. Green Bay Ave, Milwaukee, WI 53209

Phone _____

Office License _____

Date 05/13/2021

Inspector License _____

Contact Information

Name Bill Ghrist

Role Manager of Energy and Systems Integration

E-Mail bghrist@wccnet.edu

Phone 17346045511

Building Notes

- 1. Annual Sprinkler Alarm Inspection: June 2020

Tested and inspected all Water Flow Switches, Tamper Switches, & Valves associated with the Sprinkler System.

INSPECTION RESULTS SUMMARY				
DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
Clean Agent Rechargeable	7	0	0	0
Extinguisher - CO2	1	0	0	0
Extinguisher - Dry Chemical	15	0	0	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
Extinguisher - CO2	1	0	0	0
Extinguisher - Dry Chemical	15	0	0	0
Clean Agent Rechargeable	7	0	0	0



FIRE EXTINGUISHER

Customer Information

Name Washtenaw Community College

Building Information

Name Damon Flowers (Plant Operations)

Address 4800 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US

Inspection Information

Name Fire Extinguisher

SR# 48245722

Frequency Annual

Timezone GMT-05:00

Account Information

Name Johnson Controls North America

Address 6200 shamrock court Dublin Ohio 43017

Phone _____

Office 54-41-1041

License _____

Date 12/15/2020

Inspector 54-25-4199

License _____

INSPECTION RESULTS SUMMARY				
DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
Extinguisher - Clean Agent	1	1	0	0
Extinguisher - CO2	1	1	0	0
Extinguisher - Dry Chemical	5	4	1	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
Extinguisher - Dry Chemical	5	0	1	0
Extinguisher - CO2	1	0	0	0
Extinguisher - Clean Agent	1	0	0	0

DEVICE DEFICIENCIES									
LOCATION	DESCRIPTION	ADDRESS	DEVICE	MAKE	MODEL	BARCODE	DATE OF TEST	TYPE	IMAGES
—	Front door	—	Extinguisher - Dry Chemical	Sy0515	Kb00388698	321001328	12/14/2020	FUNCTIONAL FAILURE	APPENDIX 1.1
FAILURE REASON: <i>Due for hydro</i>									



FIRE EXTINGUISHER

Customer Information

Name Washtenaw Community College

Building Information

Name Health Fitness Ctr HFC

Address 4833 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US

Inspection Information

Name Fire Extinguisher

SR# N/A

Frequency Annual

Timezone GMT-05:00

Account Information

Name Johnson Controls North America

Address 6200 shamrock court Dublin Ohio 43017

Phone _____

Office 54-41-1041

License _____

Date 12/17/2020

Inspector 54-25-4199

License _____

Contact Information

Name Bill Ghrist

Role Manager of Energy and Systems Integration

E-Mail bghrist@wccnet.edu

Phone 17346045511

Building Notes

- 1. Annual Sprinkler Alarm Inspection: June 2020

Tested and Inspected all Water Flow Switches, Tamper Switches, & Valves associated with the Sprinkler System.

INSPECTION RESULTS SUMMARY

DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
Clean Agent Rechargeable	1	1	0	0
Extinguisher - CO2	2	2	0	0
Extinguisher - Dry Chemical	27	26	1	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
Extinguisher - Dry Chemical	27	1	1	0
Extinguisher - CO2	2	0	0	0
Clean Agent Rechargeable	1	0	0	0



FIRE EXTINGUISHER

Customer Information

Name Washtenaw Community College

Building Information

Name Family Education FE

Address 4800 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US

Inspection Information

Name Fire Extinguisher

SR# 48245712

Frequency Annual

Timezone GMT-05:00

Account Information

Name Johnson Controls North America

Address 6200 shamrock court Dublin Ohio 43017

Phone _____

Office 54-41-1041

License _____

Date 12/17/2020

Inspector 54-25-4199

License _____

INSPECTION RESULTS SUMMARY				
DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
Extinguisher - Dry Chemical	6	5	1	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
Extinguisher - Dry Chemical	6	0	2	0

DEVICE DEFICIENCIES									
LOCATION	DESCRIPTION	ADDRESS	DEVICE	MAKE	MODEL	BARCODE	DATE OF TEST	TYPE	IMAGES
---	By 105	---	Extinguisher - Dry Chemical	B456	ZI361531	321001244	12/17/2020	FUNCTIONAL FAILURE	APPENDIX 1.1
<i>FAILURE REASON: Hydro</i>									



FIRE EXTINGUISHER

Customer Information

Name Washtenaw Community College

Building Information

Name Great Lakes Regional Trng

Address 4800 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US

Inspection Information

Name Fire Extinguisher

SR# 48332234

Frequency Annual

Timezone GMT-05:00

Account Information

Name Johnson Controls North America

Address 6200 shamrock court Dublin Ohio 43017

Phone _____

Office 54-41-1041

License _____

Date 12/17/2020

Inspector License 54-25-4199

Contact Information

Name Bill Ghrist

Role Manager of Energy and Systems Integration

E-Mail bghrist@wccnet.edu

Phone 17346045511

Building Notes

1. Annual Sprinkler Alarm Inspection: June 2020

Tested and inspected all Water Flow Switches, Tamper Switches, & Valves associated with the Sprinkler System.

INSPECTION RESULTS SUMMARY				
DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
Clean Agent Rechargeable	1	1	0	0
Extinguisher - CO2	5	5	0	0
Extinguisher - Dry Chemical	8	8	0	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
Extinguisher - Dry Chemical	8	3	0	0
Clean Agent Rechargeable	1	0	0	0
Extinguisher - CO2	5	0	0	0



FIRE EXTINGUISHER

Customer Information

Name Washtenaw Community College

Building Information

Name Gunder Myran GM

Address 4800 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US

Inspection Information

Name Fire Extinguisher

SR# 48332240

Frequency Annual

Timezone GMT-05:00

Account Information

Name Johnson Controls North America

Address 6200 shamrock court Dublin Ohio 43017

Phone _____

Office 54-41-1041

License _____

Date 12/16/2020

Inspector 54-25-4199

License _____

Contact Information

Name Bill Ghrist

Role Manager of Energy and Systems Integration

E-Mail bghrist@wccnet.edu

Phone 17346045511

INSPECTION RESULTS SUMMARY				
DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
Clean Agent Rechargeable	3	2	1	0
Extinguisher - CO2	20	15	5	0
Extinguisher - Dry Chemical	21	10	11	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
Extinguisher - Dry Chemical	21	7	12	0
Clean Agent Rechargeable	3	0	2	1
Extinguisher - CO2	20	0	0	0

DEVICE DEFICIENCIES									
LOCATION	DESCRIPTION	ADDRESS	DEVICE	MAKE	MODEL	BARCODE	DATE OF TEST	TYPE	IMAGES
—	Dry chem FL01 Gunder Myran	—	Extinguisher - Dry Chemical	—	SF-693083	321000743	12/15/2020	FUNCTIONAL FAILURE	APPENDIX 1.1
FAILURE REASON: <i>Hydro</i>									
Scanned on 12/15/2020									

FIRE EXTINGUISHER

Customer Information

Name Washtenaw Community College

Building Information

Name Henry Landau Skill Trades

Address 4800 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US

Inspection Information

Name Fire Extinguisher

SR# 48245722

Frequency Annual

Timezone GMT-05:00

Account Information

Name Johnson Controls North America

Address 6200 shamrock court Dublin Ohio 43017

Phone _____

Office 54-41-1041

License _____

Date 12/15/2020

Inspector 54-25-4199

License _____

Contact Information

Name Bill Ghrist

Role Manager of Energy and Systems Integration

E-Mail bghrist@wccnet.edu

Phone 17346045511

Building Notes

- Annual Sprinkler Alarm Inspection: June 2020

Tested and Inspected all Water Flow Switches, Tamper Switches, and Valves associated with the Sprinkler System.

INSPECTION RESULTS SUMMARY

DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
Extinguisher - CO2	1	0	1	0
Extinguisher - Dry Chemical	4	4	0	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
Extinguisher - CO2	1	0	0	0
Extinguisher - Dry Chemical	4	1	0	0



FIRE EXTINGUISHER

Customer Information

Name Washtenaw Community College

Building Information

Name Crane Lib Arts Science LA,

Address 4800 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US

Inspection Information

Name Fire Extinguisher

SR# 48245710

Frequency Annual

Timezone GMT-05:00

Account Information

Name Johnson Controls North America

Address 6200 shamrock court Dublin Ohio 43017

Phone _____

Office 54-41-1041

License _____

Date 12/17/2020

Inspector 54-25-4199

License _____

INSPECTION RESULTS SUMMARY				
DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
Clean Agent Rechargeable	4	2	2	0
Extinguisher - Clean Agent	2	2	0	0
Extinguisher - CO2	19	11	8	0
Extinguisher - Dry Chemical	77	58	19	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
Extinguisher - CO2	19	0	0	0
Extinguisher - Dry Chemical	77	15	22	3
Clean Agent Rechargeable	4	0	0	2
Extinguisher - Clean Agent	2	1	1	0

DEVICE DEFICIENCIES									
LOCATION	DESCRIPTION	ADDRESS	DEVICE	MAKE	MODEL	BARCODE	DATE OF TEST	TYPE	IMAGES
Basement	Basement back wall	—	Extinguisher - CO2	456 cd10	Z720538	24377087	12/16/2020	FUNCTIONAL FAILURE	APPENDIX 1.1
FAILURE REASON: <i>Hydro</i>									
Scanned on 12/16/2020									

FIRE EXTINGUISHER

Customer Information

Name Washtenaw Community College

Building Information

Name Grounds Maintenance

Address 4800 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US

Inspection Information

Name Fire Extinguisher

SR# 48245724

Frequency Annual

Timezone GMT-05:00

Account Information

Name Johnson Controls North America

Address 6200 shamrock court Dublin Ohio 43017

Phone _____

Office 54-41-1041

License _____

Date 12/15/2020

Inspector 54-25-4199

License _____

INSPECTION RESULTS SUMMARY				
DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
Extinguisher - CO2	2	2	0	0
Extinguisher - Dry Chemical	11	11	0	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
Extinguisher - Dry Chemical	11	1	0	0
Extinguisher - CO2	2	0	0	0

DEVICE DEFICIENCIES
 No device deficiencies in this inspection.

FIRE EXTINGUISHER

<p>Customer Information</p> <p>Name <u>Washtenaw Community College</u></p> <p>Building Information</p> <p>Name <u>Morris Lawrence ML</u></p> <p>Address <u>4800 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US</u></p> <p>Inspection Information</p> <p>Name <u>Fire Extinguisher</u></p> <p>SR# <u>48332236</u></p> <p>Frequency <u>Annual</u></p> <p>Timezone <u>GMT-05:00</u></p>	<p>Account Information</p> <p>Name <u>Johnson Controls North America</u></p> <p>Address <u>6200 shamrock court Dublin Ohio 43017</u></p> <p>Phone _____</p> <p>Office <u>54-41-1041</u></p> <p>License _____</p> <p>Date <u>12/18/2020</u></p> <p>Inspector License <u>54-25-4199</u></p> <p>Contact Information</p> <p>Name <u>Bill Ghrist</u></p> <p>Role <u>Manager of Energy and Systems Integration</u></p> <p>E-Mail <u>bghrist@wccnet.edu</u></p> <p>Phone <u>17346045511</u></p>
--	---

Building Notes

1. Annual Sprinkler Alarm Inspection: June 2020

Tested and inspected all Water Flow Switches, Tamper Switches, & Valves associated with the Sprinkler System.

INSPECTION RESULTS SUMMARY				
DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
Clean Agent Rechargeable	3	2	1	0
Extinguisher - CO2	5	3	2	0
Extinguisher - Dry Chemical	27	19	8	0
Extinguisher - Liquid	1	1	0	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
Extinguisher - Dry Chemical	27	6	6	2
Extinguisher - CO2	5	0	0	0
Clean Agent Rechargeable	3	1	0	1
Extinguisher - Liquid	1	0	0	0

FIRE EXTINGUISHER

Customer Information

Name Washtenaw Community College

Building Information

Name Parking Structure

Address 4800 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US

Inspection Information

Name Fire Extinguisher

SR# 48245714

Frequency Annual

Timezone GMT-05:00

Account Information

Name Johnson Controls North America

Address 6200 shamrock court Dublin Ohio 43017

Phone _____

Office 54-41-1041

License _____

Date 12/16/2020

Inspector 54-25-4199

License _____

Contact Information

Name Bill Ghrist

Role Manager of Energy and Systems Integration

E-Mail bghrist@wccnet.edu

Phone 17346045511

Building Notes

- Annual Sprinkler Alarm Inspection: June 2020

Tested and Inspected all Water Flow Switches, Tamper Switches, & Valves associated with the Sprinkler System.

INSPECTION RESULTS SUMMARY

DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
Extinguisher - Clean Agent	1	1	0	0
Extinguisher - Dry Chemical	7	3	4	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
Extinguisher - Dry Chemical	7	2	0	4
Extinguisher - Clean Agent	1	0	1	0



FIRE EXTINGUISHER

Customer Information

Name Washtenaw Community College

Building Information

Name Student Center SC

Address 4800 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US

Inspection Information

Name Fire Extinguisher

SR# 48245718

Frequency Annual

Timezone GMT-05:00

Account Information

Name Johnson Controls North America

Address 5757 N. Green Bay Ave, Milwaukee, WI 53209

Phone _____

Office _____

License _____

Date 12/22/2020

Inspector License _____

Contact Information

Name Bill Ghrist

Role Manager of Energy and Systems Integration

E-Mail bghrist@wccnet.edu

Phone 17346045511

Building Notes

- Annual Sprinkler Alarm Inspection: June 2020
 Tested and inspected all Water Flow Switches, Tamper Switches, & Valves associated with the Sprinkler System.

INSPECTION RESULTS SUMMARY				
DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
ABC Extinguisher	43	42	1	0
Clean Agent Rechargeable	3	1	2	0
Extinguisher - Clean Agent	2	2	0	0
Extinguisher - CO2	15	10	5	0
Extinguisher - Dry Chemical	2	1	1	0
Extinguisher - Liquid	4	4	0	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
ABC Extinguisher	43	1	9	0
Extinguisher - CO2	15	0	0	0
Extinguisher - Dry Chemical	2	0	0	1



FIRE EXTINGUISHER

Customer Information

Name Washtenaw Community College

Building Information

Name Shipping and Receiving

Address 4800 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US

Inspection Information

Name Fire Extinguisher

SR# N/A

Frequency Annual

Timezone GMT-05:00

Account Information

Name Johnson Controls North America

Address 6200 shamrock court Dublin Ohio 43017

Phone _____

Office 54-41-1041

License _____

Date 12/15/2020

Inspector 54-25-4199

License _____

Contact Information

Name Bill Ghrist

Role Manager of Energy and Systems Integration

E-Mail bgheist@wccnet.edu

Phone 17346045511

Building Notes

1. Annual Sprinkler Alarm Inspection: June 2020

Tested and inspected all Water Flow Switches, Tamper Switches, & Valves associated with the Sprinkler System.

INSPECTION RESULTS SUMMARY

DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
ABC Extinguisher	8	8	0	0
Extinguisher - Dry Chemical	11	11	0	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
ABC Extinguisher	8	2	2	0
Extinguisher - Dry Chemical	11	2	0	0

DEVICE DEFICIENCIES

No device deficiencies in this inspection.



FIRE EXTINGUISHER

Customer Information

Name Washtenaw Community College

Building Information

Name Technical Industrial TI

Address 4800 E Huron River Dr, ANN ARBOR, MI, 48105 4800, US

Inspection Information

Name Fire Extinguisher

SR# 48245720

Frequency Annual

Timezone GMT-05:00

Account Information

Name Johnson Controls North America

Address 6200 shamrock court Dublin Ohio 43017

Phone _____

Office 54-41-1041

License _____

Date 12/16/2020

Inspector License 54-25-4199

Contact Information

Name Bill Ghrist

Role Manager of Energy and Systems Integration

E-Mail bghrist@wccnet.edu

Phone 17346045511

Building Notes

1. Annual Sprinkler Alarm Inspection: June 2020

Tested and inspected all Water Flow Switches, Tamper Switches, & Valves associated with the Sprinkler System.

INSPECTION RESULTS SUMMARY				
DEVICE TYPE	INVENTORY COUNT	PASSED	FAILED	CANNOT INSPECT
ABC Extinguisher	4	3	1	0
Clean Agent Rechargeable	1	1	0	0
Extinguisher - Clean Agent	11	7	4	0
Extinguisher - CO2	10	9	1	0
Extinguisher - Dry Chemical	23	15	8	0

COMING 6 YEAR MAINTENANCE DUE

DEVICE TYPE	TOTAL	IN THE NEXT 3 YEARS	NEXT YEAR	OVERDUE
Extinguisher - CO2	10	0	0	0
Extinguisher - Dry Chemical	23	5	7	3
ABC Extinguisher	4	0	3	1
Extinguisher - Clean Agent	11	2	4	3